



1103 445429

NIST
PUBLICATIONS

NISTIR 4381

**Center for Electronics and
Electrical Engineering**

Technical Progress Bulletin

Covering Center Programs,
January to March 1990,
with 1990 CEEE Events Calendar

**U.S. DEPARTMENT OF COMMERCE
National Institute of Standards
and Technology
Center for Electronics and
Electrical Engineering
Semiconductor Electronics Division
Gaithersburg, MD 20899**

August 1990

90-1

**U.S. DEPARTMENT OF COMMERCE
Robert A. Mosbacher, Secretary
NATIONAL INSTITUTE OF STANDARDS
AND TECHNOLOGY
John W. Lyons, Director**

NIST

C
00
56
4381
990
2

NATIONAL INSTITUTE OF STANDARDS &
TECHNOLOGY
Research Information Center
Gaithersburg, MD 20899

DATE DUE

[illegible]

**Center for Electronics and
Electrical Engineering**

Technical Progress Bulletin

Covering Center Programs,
January to March 1990,
with 1990 CEEE Events Calendar

**U.S. DEPARTMENT OF COMMERCE
National Institute of Standards
and Technology
Center for Electronics and
Electrical Engineering
Semiconductor Electronics Division
Gaithersburg, MD 20899**

August 1990

90-1



**U.S. DEPARTMENT OF COMMERCE
Robert A. Mosbacher, Secretary
NATIONAL INSTITUTE OF STANDARDS
AND TECHNOLOGY
John W. Lyons, Director**

INTRODUCTION TO AUGUST 1990 ISSUE OF THE CEEE TECHNICAL PROGRESS BULLETIN

This is the thirtieth issue of a quarterly publication providing information on the technical work of the National Institute of Standards and Technology (formerly the National Bureau of Standards) Center for Electronics and Electrical Engineering. This issue of the CEEE Technical Progress Bulletin covers the first quarter of calendar year 1990.

Organization of Bulletin: This issue contains abstracts for all Center papers released for publication by NIST in the quarter and citations and abstracts for Center papers published in the quarter. Entries are arranged by technical topic as identified in the table of contents and alphabetically by first author under each subheading within each topic. Unpublished papers appear under the subheading "Released for Publication." Papers published in the quarter appear under the subheading "Recently Published." Following each abstract is the name and telephone number of the individual to contact for more information on the topic (usually the first author). This issue also includes a calendar of Center conferences and workshops planned for calendar year 1990 and a list of sponsors of the work.

Center for Electronics and Electrical Engineering: Center programs provide national reference standards, measurement methods, supporting theory and data, and traceability to national standards.

The metrological products of these programs aid economic growth by promoting equity and efficiency in the marketplace, by removing metrological barriers to improved productivity and innovation, by increasing U. S. competitiveness in international markets through facilitation of compliance with international agreements, and by providing technical bases for the development of voluntary standards for domestic and international trade. These metrological products also aid in the development of rational regulatory policy and promote efficient functioning of technical programs of the Government.

The work of the Center is divided into two major programs: the Semiconductor Technology Program, carried out by the Semiconductor Electronics Division in Gaithersburg, MD, and the Signals and Systems Metrology Program, carried out by the Electricity Division in Gaithersburg and the Electromagnetic Fields and Electromagnetic Technology Divisions in Boulder, CO. Key contacts in the Center are given on the back cover; readers are encouraged to contact any of these individuals for further information. To request a subscription or for more information on the Bulletin, write to CEEE Technical Progress Bulletin, National Institute of Standards and Technology, Metrology Building, Room B-358, Gaithersburg, MD 20899 or call (301) 975-2220.

Center sponsors: The Center Programs are sponsored by the National Institute of Standards and Technology and a number of other organizations, in both the Federal and private sectors; these are identified on page 30.

Note on Publication Lists: Guides to earlier as well as recent work are the publication lists covering the work of each division. These lists are revised and reissued on an approximately annual basis and are available from the originating division. The current set is identified in the Additional Information section, page 23.

TABLE OF CONTENTS

INTRODUCTION	inside title page
SEMICONDUCTOR TECHNOLOGY PROGRAM	2
Silicon Materials	2
Compound Semiconductor Materials	2
Analysis Techniques	3
Photodetectors	3
Integrated Circuit Test Structures	3
Device Physics and Modeling	4
Other Semiconductor Metrology Topics	4
SIGNALS & SYSTEMS METROLOGY PROGRAM	5
FAST SIGNAL ACQUISITION, PROCESSING, & TRANSMISSION	5
Waveform Metrology	5
DC & Low Frequency Metrology	7
Fundamental Electrical Measurements	8
Cyroelectronic Metrology	9
Laser Metrology	12
Antenna Metrology	12
Microwave & Millimeter-Wave Metrology	13
Electro-Optic Metrology	13
Electromagnetic Properties	15
Complex Testing	15
Other Fast Signal Topics	16
ELECTRICAL SYSTEMS	17
Power Systems Metrology	17
Superconductors	20
Magnetic Materials & Measurements	21
Other Electrical Systems Topics	22
ELECTROMAGNETIC INTERFERENCE	22
Radiated Electromagnetic Interference	22
Conducted Electromagnetic Interference	23
ADDITIONAL INFORMATION	23
1990 CEEE CALENDAR	29
SPONSOR LIST	30
KEY CONTACTS IN CENTER, CENTER ORGANIZATION	back cover

SEMICONDUCTOR TECHNOLOGY PROGRAMSilicon Materials

Released for Publication

Mayo, S., Lowney, J.R., Roitman, P., and Novotny, D.B., **Persistent Photoconductivity in SIMOX Film Structures.**

Photoinduced transient spectroscopy (PITS) was used to measure the persistent photoconductive (PPC) response in n-type SIMOX film resistors. A broadband, single-shot, flashlamp-pumped dye laser pulse was used to photoexcite interband electrons in the film, and the excess carrier population decay was measured at temperatures in the 60- to 200-K range. The PPC signals exhibit nonexponential character, and the conductivity transients are recorded as a function of temperature for variable periods up to 30 s. The photoconductive data are analyzed by using the Queisser and Theodorou potential barrier model, and a logarithmic time decay dependence is confirmed for the first time in SIMOX material. The hole-trap density at the conductive film-buried silica interface is calculated to be in the high 10^{15} cm^{-3} to low 10^{16} cm^{-3} range. The sensitivity of PITS is demonstrated to be appropriate for characterization of the SIMOX interface structure and for material qualification.

[Contact: Santos Mayo, (301) 975-2045]

Recently Published

Mayo, S., Fassett, J.D., Kingston, H.M., and Walker, R.J., **Measurement of Vanadium Impurity in SIMOX Material by Isotope Dilution and Resonance Ionization Mass Spectrometry**, Analytical Chemistry, Vol. 62, No. 3, pp. 240-244 (February 1, 1990).

The combined analytical capabilities of isotope dilution, laser-induced resonance ionization spectroscopy, and mass spectrometry, integrated in the

resonance ionization mass spectrometry technique (RIMS), have been evaluated as a tool for quantitative elemental impurity analysis of SIMOX, a new silicon-based material prepared by oxygen implants. The vanadium impurity content was measured in the top crystalline SIMOX film and the oxygen-synthesized buried oxide layer in commercial wafers, resulting in a $0.1 \mu\text{g/g} \pm 20$ percent, or $1.7 \times 10^{15} \text{ atoms/cm}^3$. A similar analysis on the substrate bulk shows about thirty times lower vanadium impurity levels. The origin of this contamination is linked to the oxygen implant although no modeling for it is offered here. The sensitivity of RIMS to vanadium is in the pg/g range. The accuracy of results is determined by the blank, in view of the low total vanadium in the specimen. [Contact: Santos Mayo, (301) 975-2045]

Compound Semiconductor Materials

Released for Publication

Pellegrino, J., Griffin, J., Myers, L., and Spencer, M., **Beryllium Doping in MBE-Grown GaAs and AlGaAs**, to be published in the Proceedings of the Materials Research Society Symposium, Boston, Massachusetts, November 27-December 2, 1989.

Beryllium is an effective p-dopant in GaAs and AlGaAs and plays an important role in device characterizations of hetero bipolar transistors. This work addresses the doping and mobility properties for two series of beryllium-doped samples: GaAs and AlGaAs. Within each series the doping ranged between levels of $3 \times 10^{15} \text{ cm}^{-3}$ to $5 \times 10^{19} \text{ cm}^{-3}$. Mobility and carrier concentrations were obtained through Hall and Polaron measurements. The doping concentration results suggest the onset of carrier compensation at higher doping levels. One possible explanation is that for high doping levels, Be is incorporated as interstitial donors. A thermodynamic model is used to explain the observa-

Compound Semiconductor Matls. (cont'd.)

tions.

[Contact: Joseph G. Pellegrino, (301) 975-2123]

Analysis Techniques

Released for Publication

Bell, M.I., and McKeown, D.A., **High-Precision Optical Reflectometer for the Study of Semiconductor Materials and Structures.**

The design and performance of a high-precision optical reflectometer are described. This instrument has been optimized for measuring the specular reflectivity of thin films and multi-layer structures of interest in semiconductor technology. Its design emphasizes high spectral and spatial resolution, photometric accuracy, and stray light rejection. Use of a spectrometer drive linear in wavenumber (energy) and a flexible data acquisition system facilitates data analysis. The performance of the reflectometer is demonstrated using a set of specimens consisting of silicon-dioxide layers on silicon substrates for which the oxide thicknesses had been determined by ellipsometry. Excellent agreement is obtained between the thicknesses derived from the reflectivity spectra and those determined ellipsometrically.

[Contact: Michael I. Bell, (301) 975-2044]

Photodetectors

Released for Publication

Geist, J., Migdall, A., and Baltes, H., **Shape of the Silicon Absorption Coefficient Spectrum Near 1.63 eV.**

We report high-precision, high-spectral-resolution measurements of the absorption coefficient of silicon in the region from 1.61 to 1.65 eV. Our results, together with a simulation of the effect of a second indirect

transition on the absorption coefficient of silicon, suggest that features reported by Forman et al. (1974) and by Hulthen and Nilsson (1976) around 1.63 eV are not real, and that the second indirect transition in silicon has yet to be detected in absorption coefficient spectra.

[Contact: Jon Geist, (301) 975-2066]

Kohler, R., Geist, J., and Bonhoure, J., **Generalized Photodiode Self-Calibration Formula.**

We have derived the photodiode self-calibration formula for calculating the internal quantum efficiency of silicon photodiodes from the results of up to three independent self-calibration experiments, and from the results of the oxide-bias and reverse-bias experiments in conjunction with a calculation of the effect of Auger recombination. We show that the formula published elsewhere for these three effects is not correct.

[Contact: Jon Geist, (301) 975-2066]

Integrated Circuit Test Structures

Released for Publication

Khera, D., Cresswell, M.W., Linholm, L.W., Ramanathan, G., Buzzeo, J., and Nagarajan, A., **Knowledge Extraction Techniques for Expert-System-Assisted Wafer Screening**, to be published in the Proceedings of the International Semiconductor Manufacturing Science Symposium, Burlingame, California, May 21-23, 1990.

This paper describes a procedure for using induction-based classification techniques for identifying relationships between work-in-process (WIP) test structure data and future IC yield at wafer test on a wafer-by-wafer or lot-by-lot basis. The relationships are extracted from databases of previously processed WIP wafer test structure measurements and final wafer yield. They are presented in the form of rules relating WIP data to final yield. It is

IC Test Structures (cont'd.)

further shown that these rules, when incorporated into expert systems, can advise the human operator responsible for screening wafers which are likely to produce sub-marginal yield if processed to completion. These rules also identify the WIP test structure parameters and values which have historically provided the highest and lowest final wafer yields.

[Contact: Dheeraj Khera, (301) 975-2240]

Recently Published

Cresswell, M.W., Khera, D., Linholm, L.W., and Schuster, C.E., **Test Structure Data Classification Using a Directed Graph Approach**, Proceedings of the IEEE 1990 International Conference on Microelectronic Test Structure, San Diego, California, March 5-7, 1990, Vol. 3, pp. 193-198 (March 1990).

This paper introduces directed graph techniques to serve as an expert system rule generator by classifying selections of tested wafers into groups based on similarities of the spatial distributions of their parametric test structure measurements. The rules can be used to supplement rules derived by other means for diagnostic process analysis, work-in-process wafer screening, and yield and reliability management.

[Contact: Michael W. Cresswell, (301) 975-2072]

Device Physics and ModelingReleased for Publication

Seabaugh, A.C., Mathias, J.J., and Bell, M.I., **Semiconductor Measurement Technology: EPROP: An Interactive FORTRAN Program for Computing Selected Electronic Properties of Gallium Arsenide and Silicon**, to be published as NIST Special Publication 400-85.

A new computer program, EPROP (an acronym for **E**lectronic **PRO**perties) is

presented for use in interpreting measurements and experiments on gallium arsenide and silicon. EPROP computes a solution of the charge balance equation in thermodynamic equilibrium for up to six different impurities. The user supplies the density, energy level, and degeneracy for each impurity, and in response the program returns as many as 28 output parameters, such as the Fermi level, carrier density, and ionized impurity densities. These can be computed as functions of the temperature (or reciprocal temperature) or the density, energy, or degeneracy of any of the six possible impurities. Listings can also be obtained of various temperature-dependent parameters, such as the bandgap, densities of states, and effective masses. The interactive features of the program allow the user to send the output data to any combination of destinations: a terminal, a listing file, and/or up to four graphic output files, all at the user's direction. The user is also given freedom and ability to customize the data output to these destinations through menu-driven controls. The program is written in ANSI standard FORTRAN 77 and has been successfully compiled and run on both mainframe and microcomputers. Documentation is provided to assist the interested user in customizing the program for special applications, extracting portions for use elsewhere, or modifying the code to treat semiconductors other than silicon and gallium arsenide.

[Contact: Michael I. Bell, (301) 975-2044]

Other Semiconductor Metrology TopicsReleased for Publication

Parameswaran, M., Robinson, A.M., Blackburn, D.L., and Geist, J., **Micromachined Thermal and Visible Radiation Source Using a Commercial CMOS Process**.

Fabrication of a thermally isolated micromechanical structure capable of

Other Semiconductor Topics (cont'd.)

generating visible as well as thermal radiation is described. The fabrication process is completely compatible with a commercial IC process, viz., CMOS. Compatibility is achieved by providing a suitable layout for implementation by the CMOS foundry using their regular process sequence. After commercial production of the CMOS chips, a maskless dip in ethylenediamine-pyrocatechol (EDP) is performed to realize the micromechanical structure. The final device is a suspended plate structure formed out of the field oxide and the CVD oxides of the CMOS process sandwiching a pair of polysilicon resistors. A typical device under test generated a silicon weighted ($\lambda < 1.25 \mu\text{m}$) radiant intensity of 8.2×10^{12} photons/second/steradian for an input electrical power of 35 mW. The computed emittance (radiance) for the incandescent area of the device yielded an equivalent blackbody temperature of 1400 K.

[Contact: Jon Geist, (301) 975-2066]

Recently Published

Suehle, J.S., and Schafft, H.A., **Current Density Dependence of Electromigration t_{50} Enhancement Due to Pulsed Operation**, Proceedings of the 1990 International Reliability Physics Symposium, New Orleans, Louisiana, March 27-29, 1990, pp. 106-110 (March 1990).

Two effects that complicate the electromigration characterization of metallization for pulsed stress have been observed. One is the dependence of the t_{50} enhancement (due to pulsed operation) on current density, and the other is a decrease of this enhancement over a range of frequencies (0.2 to 2 MHz) that is connected with the joule heating. These effects are discussed in terms of changes in the buildup and relaxation response times of the excess vacancy concentration.

[Contact: John S. Suehle, (301) 975-2247]

SIGNALS & SYSTEMS METROLOGY PROGRAM

FAST SIGNAL ACQUISITION, PROCESSING, AND TRANSMISSION

Waveform Metrology

Recently Published

Gans, W.L., **Dynamic Calibration of Oscilloscopes and Waveform Recorders Using Pulse Standards**, Conference Record of the IEEE Instrumentation and Measurement Technology Conference, San Jose, California, February 13-15, 1990, pp. 246-250 (1990).

The purpose of this presentation is to convince the reader/listener of two key points. The first is that virtually no one calibrates oscilloscopes/waveform recorders properly and completely at present. The second is that, in most cases, the tools are now available to perform these complete and proper calibrations when the application requires it. After a brief introduction describing the current methods used to calibrate oscilloscopes, the problems associated with these methods are discussed and illustrated. The solutions to these problems are then described.

[Contact: William L. Gans, (303) 497-3538]

Laug, O.B., **A High-Current, Very-Wide-Band Transconductance Amplifier**, IEEE Transactions on Instrumentation and Measurement, Vol. 39, No. 1, pp. 42-47 (February 1990).

A new design approach for a high-current, very-wide-band transconductance amplifier is described. The approach is based on paralleling the input and output of complementary unipolar current-mirror cells. Each cell has a fixed current gain determined by the ratio of two resistors. A differential input voltage-to-current circuit drives the cell array. The design has the advantage of avoiding the need for a single low-resistance current-sensing

Waveform Metrology (cont'd)

resistor and the attendant problems inherent in such resistors. Although the concept is still under development, a prototype of the cell-based transconductance amplifier was implemented with ten positive and ten negative current cells to gain some experimental familiarity with the approach, in addition to providing verification of computer simulation results. The prototype transconductance amplifier is dc coupled, has a 3-dB bandwidth of about 750 kHz, and can deliver up to 35 A rms at 100 kHz with an output compliance voltage of 5 V rms. Other important characteristics, such as output load regulation and dc offsets, are discussed.

[Contact: Owen B. Laug, (301) 975-2412]

Oldham, N.M., Bruce, W.F., Fu, C.M., and Smith, A.G., **An Intercomparison of AC Voltage Using a Digitally Synthesized Source**, IEEE Transactions on Instrumentation and Measurement, Vol. 39, No. 1, pp. 6-9 (February 1990).

An ac voltage intercomparison was conducted by the National Institute of Standards and Technology (NIST) to determine the consistency of ac voltage measurements made at various standards laboratories. The transport standard used for this purpose was an NIST-developed digitally synthesized sinusoidal voltage source whose rms value is calculated by measuring the dc level of each of the steps used to synthesize the sine wave. The uncertainty of the calculated voltage at the 7-V level is typically within ± 10 parts per million (ppm) from 15 Hz to 7.8 kHz. This approach represents a technique of referring ac voltage to a standard dc voltage, which is independent of the traditional thermal-voltage-converter approach. Preliminary measurements made at each of the participating laboratories agree with the calculated value to within ± 20 ppm. This would indicate

that, at the 7-V level in the low audio-frequency range, the ac voltage measurement techniques implemented at these laboratories are near the state of the art.

[Contact: Nile M. Oldham, (301) 975-2408]

Souders, T.M., Flach, D.R., and Blair, J.J., **Step and Frequency Response Testing of Waveform Recorders**, Proceedings of the IEEE Instrumentation and Measurement Technology Conference, San Jose, California, pp. 214-220, February 13-15, 1990.

Tutorial material is presented to aid in measuring the step response of waveform recorders, and to compute other parameters which may be derived from it. Parameters considered include impulse response, transition duration, settling time, and complex frequency response. The measurement approaches follow those recommended in the IEEE "Trial Use Standard for Digitizing Waveform Recorders." Illustrated examples are given, and guidelines on the choice of step generators are also included.

[Contact: T. Michael Souders, (301) 975-2406]

Souders, T.M., Flach, D.R., Hagwood, C., and Yang, G., **The Effects of Timing Jitter in Sampling Systems**, IEEE Transactions on Instrumentation and Measurement, Vol. 39, No. 1, pp. 80-85 (February 1990).

Timing jitter generally causes a bias in the amplitude estimates of sampled waveforms. Equations are developed for computing the bias in both the time and frequency domains. Two principal estimators are considered: the sample mean and the so-called Markov estimator used in some equivalent-time sampling systems. Examples are given using both real and simulated data.

[Contact: T. Michael Souders, (301) 975-2406]

DC & Low Frequency Metrology

Released for Publication

Cage, M.E., Yu, D., Jeckelmann, B.M., Steiner, R.L., and Duncan, R.V., **Investigating the Use of Multimeters to Measure Quantized Hall Resistance Standards**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

A new generation of digital multimeters was used to compare the ratios of the resistances of wire-wound reference resistors and quantized Hall resistances. The accuracies are better than 0.1 ppm for ratios as large as 4:1 if the multimeters are calibrated with a Josephson array.

[Contact: Marvin E. Cage, (301) 975-4248]

Field, B.F., and Oldham, N.M., **Digital Source for a New Impedance Bridge**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

A digitally-synthesized source has been designed to provide two sine wave outputs with an accurately known adjustable phase shift in the second channel for use with a proposed new impedance bridge.

[Contact: Bruce F. Field, (301) 975-4230]

Kinard, J.R., Huang, D.X., and Rebul-dea, G., **RF-DC Differences of Thermal Voltage Converters Arising from Input Connectors**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

The rf-dc differences of thermal voltage converters caused by skin effect and transmission line effects of different length input structures have been previously studied. Discrepancies do exist, however, between simple mathe-

matical models and measured results for commonly used input connectors. This paper reports a study of these discrepancies.

[Contact: Joseph R. Kinard, (301) 975-4250]

Kinard, J.R., Huang, D.X., and Novotny, D.B., **Hybrid Construction of Multijunction Thermal Converters**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

Using thin-film and thick-film technologies, multijunction thermal converters have been designed for frequencies ranging from audio up to tens of megahertz and for heater currents from a few milliamperes up to hundreds of milliamperes. This paper describes these designs and the early production of prototype converters.

[Contact: Joseph R. Kinard, (301) 975-4250]

Kinard, J.R., Lipe, T.E., and Childers, C.B., **Ac-dc Difference Relationships for Current Shunt and Thermal Converter Combinations**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

This paper describes the relationship between the overall ac-dc difference of a thermal converter and current shunt combination and the characteristics of the separate thermal converter and current shunt. As a consequence of the analysis, an expression predicting the ac-dc difference of a thermal converter/shunt combination when thermoelements are interchanged is presented, and data illustrating the agreement between values of ac-dc difference and values predicted by the analysis are given.

[Contact: Joseph R. Kinard, (301) 975-4250]

Oldham, N.M., and Henderson, R.M., **New Low-Voltage Standards in the DC to 1 MHz Frequency Range**, to be published in

DC & Low Frequency Metrology (cont'd.)

the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

Several new techniques for measuring the rms value of 1- to 600-mV signals have been developed and compared to existing thermal transfer standards. Differences between the techniques at 100 mV are typically within ± 20 ppm in the audio-frequency range and within ± 100 ppm out to 1 MHz.

[Contact: Nile M. Oldham, (301) 975-2408]

Steiner, R., and Astalos, R., **Improvements for Automating Voltage Calibrations Using a 10-V Josephson Array**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

With three novel improvements, a voltage standard system based on a 10-V Josephson array is totally automated. A commercial standard cell scanner controls switching for calibrating either Zener references or digital voltmeters, a programmable attenuator helps in obtaining voltage steps, and measurements of DVM noise help in verifying array stability.

[Contact: Richard Steiner, (301) 975-4226]

Waltrip, B.C., and Oldham, N.M., **Performance Evaluation of a New Audio-Frequency Power Bridge**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

Several techniques for measuring active and reactive power in the 30-Hz to 20-kHz frequency range are described. These approaches were developed to evaluate a new high-accuracy, audio-frequency power bridge that is based on ac voltage and impedance measurements.

[Contact: Bryan C. Waltrip, (301) 975-2438]

Fundamental Electrical Measurements

Released for Publication

Olsen, P.T., Tew, W.L., Elmquist, R.E., and Williams, E.R., **Monitoring the Mass Standard: A Comparison of Mechanical to Electrical Power**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

Except for the kilogram, all of the base units of the International System of Units (SI) are defined by invariant fundamental constants. The on-going NIST (formerly NBS) absolute watt experiment shows the promise of being able to monitor the stability of the mass standard to better than 0.05 ppm. We discuss our latest results and future possibilities.

[Contact: P. Thomas Olsen, (301) 975-6553]

Williams, E.R., **High Accuracy Determination of the Fine Structure Constant via Measurement of the Proton Gyromagnetic Ratio**.

The latest experiment at the National Institute of Standards and Technology to measure the gyromagnetic ratio of the proton in H_2O , γ'_p , by the low-field method has an uncertainty of 0.11 ppm for γ'_p (low). Using this experimental result, a value for the fine structure constant $\alpha^{-1} = 137.0359840(51)$ (0.037 ppm) can be calculated. The uncertainty in α is limited by the uncertainty in the γ'_p experiment. The most difficult part of this experiment was constructing a 2.1-m long solenoid with a precision of a few μm , then measuring its critical dimensions to 0.05 μm . Instead of measuring the wire locations, we measured the location of the current placed in each winding turn using the magnetic field produced by the current in that turn. We accurately measured the solenoid current in terms of the Josephson volt and Quantum Hall resistance. The resultant magnetic field was uniform to 1 in 10^7 over 7-cm

Fundamental Electrical Meas. (cont'd.)

diameter sphere. The precession frequency was measured using NMR. When this value of α is compared with that obtained from the electron magnetic moment anomaly, a_e , using Dehmelt et al.'s results and Kinoshita's calculation, we have one of the most precise tests of QED theory. The difference between the values of α obtained from a_e and γ'_p is $(0.054 \pm 0.038 \text{ ppm})$.

[Contact: Edwin R. Williams, (301) 975-6555]

Recently Published

Cage, M.E., Yu, D.Y., and Reedtz, G.M., **Observation and an Explanation of Breakdown of the Quantum Hall Effect**, Journal of Research of the National Institute of Standards and Technology, Vol. 95, No. 1, pp. 93-99 (January-February 1990).

We observe spatially localized breakdown of the nearly dissipationless quantum Hall effect regime into a set of discrete dissipative states in wide, high-quality GaAs/AlGaAs samples. The phenomenon can be explained by quasi-elastic inter-Landau level scattering. We propose the existence of a new, highly efficient population inversion mechanism and the possible existence of an acoustic phonon laser.

[Contact: Marvin E. Cage, (301) 975-4248]

Coogan, P.C., Ricketts, B.W., Small, G.W., Cage, M.E., Dziuba, R.F., and Shields, J.Q., **Comparisons of the NML and NIST Representations of the Ohm Using Transportable 1 Ω , 10 k Ω , 10 pF, and Quantized-Hall-Resistance Standards**, Metrologia, Vol. 26, pp. 229-234 (Springer-Verlag, 1989).

The laboratory or as-maintained ohm representations of the National Measurement Laboratory (NML) in Australia and the National Institute of Standards and Technology (NIST) in the United States have been compared by four

different methods. These methods involved the transport and intercomparison, over a 15-month time period, of three 1- Ω resistors on two occasions, one 10-k Ω resistor, three 10-pF capacitors on two occasions, and one quantized Hall device. The excellent agreement of the comparisons of the ohm representations Ω_{NML} and Ω_{NIST} obtained by the four methods provides rigorous tests of the accuracies of 15 different measurement systems used at the two laboratories. The weighted mean of the difference between Ω_{NML} and Ω_{NIST} was found to be $(1.3664 \pm 0.0081) \text{ ppm}$ for 1 January 1986.

[Contact: Marvin E. Cage, (301) 975-4248]

Van Degrift, C.T., Cage, M.E., and Girvin, S.M., **Resource Letter QHE-1: The Integral and Fractional Quantum Hall Effects**, Am. J. Phys., Vol. 58, No. 2, pp. 109-123 (February 1990).

This Resource Letter provides a guide to the literature on the integral and fractional quantum Hall effects. The letter E after an item indicates elementary level or material of general interest to persons becoming informed in the field. The letter I, for intermediate level, indicates material of somewhat more specialized nature; and the letter A indicates rather specialized or advanced material. An asterisk (*) indicates articles that we feel are especially useful or interesting; a double asterisk (**) indicates those articles to be included in an accompanying reprint book.

[Contact: Craig T. Van Degrift, (301) 975-4248]

Cryoelectronic Metrology

Released for Publication

Grossman, E.N., McDonald, D.G., and Sauvageau, J.E., **2-D Analysis of Microbolometer Arrays**.

A two-dimensional, time-dependent analysis is made of array-compatible

Cryoelectronic Metrology (cont'd.)

bolometers directly deposited onto a single substrate. It applies both to antenna-coupled and surface-absorbing configurations. Unlike previous spherically symmetric treatments, it allows analysis of thermal crosstalk between closely neighboring detectors and of the effects of finite substrate thickness. It is shown that in a closely-packed array of surface-absorbing detectors, thermal crosstalk generally degrades the array's resolution more severely than optical (diffractive) crosstalk. Diffraction-limited resolution with surface-absorbing detectors is only possible by sacrificing either thermal resistance, and therefore sensitivity, or filling factor. With practical substrate thicknesses of $L > L_{\min} \approx 50 \mu\text{m}$, a closely-packed, diffraction-limited array is limited to a thermal resistance of $Z_t < 0.08 (\kappa L_{\min})^{-1} = 16 \text{ K/mW}$, where κ is the thermal conductivity of the substrate, and the numerical value corresponds to fused quartz at 4 to 8 K. An array of antenna-coupled bolometers is not subject to this limitation since the thermally and optically sensitive areas need not be equal.

[Contact: E. N. Grossman, (303) 497-5102]

Hamilton, C.A., Kautz, R.L., Chieh, K., Stieg, M. Simmonds, M., and Avrin, W., **A 24 GHz Josephson Array Voltage Standard**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

This paper describes the design and operation of a Josephson array voltage standard which operates at 24 GHz, thus realizing substantial advantages in cost and reliability over more conventional devices which operate at 70 to 100 GHz. Typical step stability times of 20 min are more than adequate for calibrations at the 1-V level. Chips using both probe and finline microwave coupling

schemes were tested. The probe scheme was about 3 dB more efficient and allowed a smaller chip and a less expensive mount.

[Contact: Clark A. Hamilton, (303) 497-3740]

Huber, M.E., and Cromar, M.W., **Initial Characterization of Excess Low-Frequency Flux Noise in dc SQUIDs with Nb/Al-Oxide/Nb Josephson Junctions.**

We have fabricated thin-film dc SQUIDs (Superconducting QUantum Interference Devices) incorporating high-quality Nb/AlO_x/Nb tunnel junctions. The spectral density of the voltage noise of stripline SQUIDs is characterized between 1 and 2000 Hz using a commercial dc SQUID as a preamplifier. In the region studied, the noise is neither white nor 1/f-like and is proportional to the $(\partial V / \partial \Phi)^2$ over a broad range of fabrication and bias conditions. The spectral density of the flux noise, S_Φ , at 1 Hz is less than $10^{-11} \Phi_0^2 / \text{Hz}$ in a 7-pH SQUID, where $\Phi_0 = h/2e$. We have eliminated environmental sources as the origin of the observed noise. We also find the noise to be independent of the value of the shunt resistance and whether the material constituting the body of the SQUID is niobium or lead. S_Φ is inversely proportional to the junction area; however, the product of the junction area, critical current density, and SQUID self-inductance was constant for all SQUIDs tested, and other scaling relations are possible.

[Contact: Martin E. Huber, (303) 497-5423]

Huber, M.E., Cunningham, C.E., Park, G., and Cabrera, B., **Correlation of Flux States Generated by Optical Switching of a Superconducting Circuit.**

We used an optically tripped superconducting switch to change the quantum flux state of a superconducting circuit. We varied the optical pulse length over six decades between 6 ns and 10 ms and measured the correlation between successive flux states at each pulse

Cryoelectronic Metrology (cont'd.)

length. The correlations fit a simple Fokker-Planck conditional probability model.

[Contact: Martin E. Huber, (303) 497-5423]

Martinis, J.M., and Ono, R.H., Fabrication of Ultra-Small Nb-AlOx-Nb Josephson Tunnel Junctions.

We describe a fabrication process to make Nb-AlOx-Nb edge junctions with areas down to $0.0022 \mu\text{m}^2$ and with current densities from 10 to 24000 A/cm^2 . The junction conductance was low for voltages below the superconducting energy gap indicating good quality tunnel barriers. Coulomb gap measurements obtained when the junctions were in the normal state were used to find the junction capacitance. Junction capacitance as small as 0.18 fF has been measured.

[Contact: John M. Martinis, (303) 497-3597]

Peterson, R.L., Sidelobe Suppression in Small Josephson Junctions.

Many applications of Josephson junctions require that the sidelobes of the critical-current patterns as a function of magnetic field be as small as possible. The first sidelobes in small Josephson junctions are shown here to be capable of suppression below the 1% level by appropriate choice of junction geometry. For a wide variety of shaped junctions, the diffraction patterns can be expressed by simple formulas. For applications requiring long junctions, an analysis based on small junctions of the same geometry is a practical starting point.

[Contact: Robert L. Peterson, (303) 497-3750]

Recently Published

Martinis, J.M., and Kautz, R.L., Classical Phase Diffusion in Small Hysteretic Josephson Junctions,

Physical Review Letters, Vol. 63, No. 14, pp. 1507-1510 (2 October 1989).

The existence of classical phase diffusion in hysteretic junctions is demonstrated by quantitative agreement between experimental and simulated I-V curves. The simulations are based on a circuit that accurately models both the junction and its external shunting impedance at microwave frequencies. We show that the bias current at which the junction switches from the phase-diffusion state to the voltage state is sensitive to dissipation at microwave frequencies.

[Contact: John M. Martinis, (303) 497-3597]

McDonald, D.G., Superconductivity and the Quantization of Energy, Science, Vol. 247, pp. 177-182 (12 January 1990).

Ideas about quantized energy levels originated in atomic physics, but superconductivity provides energy levels with unparalleled precision: 3 parts in 10^{19} at an energy of 0.0003 eV, in recent work by Jain, Lukens, and Tsai. The fact that the myriad of interactions of 10^{12} particles in a macroscopic body, a Josephson junction, can produce sharply defined energy levels suggests a dynamical state effectively divorced from the complexities of its environment. The existence of this state, the macroscopic quantum state of superconductors, is well established, but its isolation from intrinsic perturbations has recently been shown to be extraordinary. These new results, with an improved accuracy of about 10 orders of magnitude, are discussed in the context of highly accurate results from quantum electrodynamics, atomic spectroscopy, and the standards of metrology. Further refinements in accuracy may be achievable at higher energy levels, about 12 eV, as they become available from a new series array of 18992 Josephson junctions.

[Contact: Donald G. McDonald, (303) 497-5113]

Cryoelectronic Metrology (cont'd.)

Savageau, J.E., and McDonald, D.G., **Superconducting Inductance Bolometer with Potential Photon-Counting Sensitivity: A Progress Report**, Inst. Phys. Conf. Ser. No. 92 (paper presented at the International Conference Optical Radiometry, NPL, London, England, April 12-13, 1988), pp. 39-46 (1989).

This bolometer is based on the temperature dependence of the inductance of a superconducting microstrip line. Since the device is superconducting, it has no Johnson noise. It can be impedance matched to an optimized SQUID preamplifier, the quietest of all amplifiers, and its bias current is relatively unrestricted by self-heating. We show theoretically that this device can have a sensitivity comparable to that of an optical photon counting detector, or an NEP_e of 5.4×10^{-18} W/Hz. Our experimental prototype device is designed to test the theory of operation, but not at the highest levels of sensitivity.

[Contact: Joseph E. Savageau, (303) 497-3770]

Laser Metrology

Released for Publication

Rasmussen, A.L., Case, W.E., and Sanders, A.A., **Scanning System for Measuring Uniformity of Laser Detector Response and Laser Beam Dimensions**, to be published as an NISTIR.

A computer-controlled scanning system moves a detector or a pinhole attached to a detector in a plane perpendicular to the axis of a stationary laser beam. A linear detector monitors the laser beam. The system measures the uniformity of laser detector response and the laser beam dimensions. The device to be measured is attached to computer controlled x-y translation tables that scan a maximum area of 15 cm x 15 cm with 10^{-4} cm resolution along each axis.

Detector and monitor outputs are digitized with a computer board. Output versus position is represented in contour maps and surface graphics on the computer, the plotter, or the printer. Choice of matrix dimensions and step sizes of the scanned area determine the resolution of graphics. Maximum, minimum, average, and variance data of the z output of a detector for a chosen x-y area provide additional uniformity information. High-precision fiber couplers can be used to spatially filter and/or collimate the beam. Available sources are conventional lasers from the visible and the near infrared wavelengths or laser diodes at 0.82-, 1.3-, and 1.55- μ m wavelengths. A precision positioner along the optical axis moves the measurement device and controls the size of the beam entering it. Beam dimensions and detector response data are given. This report documents the use of the system to calibrate detectors.

[Contact: Alvin L. Rasmussen, (303) 497-5367]

Antenna Metrology

Recently Published

Francis, M.H., Kremer, D.P., and Repjar, A.G., **Advanced System Characterizes Antennas to 65 GHz** [original title: Antenna Measurements at Millimeter Frequencies], *Microwaves & RF*, pp. 77 ff. (March 1990).

In the past, few antenna measurements above 30 GHz have been done by the National Institute of Standards and Technology (NIST). Recently, NIST has developed the capability to do antenna measurements at frequencies from 30 to 65 GHz. The extrapolation technique is used to determine the gain and polarization properties of antennas and probes with gains up to about 30 dB. The planar near-field technique is used for antennas with higher gains as well as for determining far-field antenna patterns for frequencies up to 50 GHz. This report describes the problems and

Antenna Metrology (cont'd.)

the solutions for providing measurement capability at these frequencies. The problems that arise are primarily due to the small wavelengths at these frequencies requiring: (1) much better accuracies in the manufacture of flanges, (2) an improved technique for making insertion loss measurements, and (3) improved probe-positioning accuracy. [Contact: Michael H. Francis, (303) 497-5873]

Microwave & Millimeter-Wave Metrology

Released for Publication

Kinard, J.R., Huang, D.X., and Novotny, D.B., **Hybrid Construction of Multijunction Thermal Converters**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

Using thin-film and thick-film technologies, multijunction thermal converters have been designed for frequencies ranging from audio up to tens of megahertz and for heater currents from a few milliamperes up to hundreds of milliamperes. This paper describes these designs and the early production of prototype converters. [Contact: Joseph R. Kinard, (301) 975-4250]

Kinard, J.R., Huang, D.X., and Rebuldela, G., **RF-DC Differences of Thermal Voltage Converters Arising from Input Connectors**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

The rf-dc differences of thermal voltage converters caused by skin effect and transmission line effects of different length input structures have been previously studied. Discrepancies do exist, however, between simple mathematical models and measured results for commonly used input connectors. This

paper reports a study of these discrepancies.

[Contact: Joseph R. Kinard, (301) 975-4250]

Recently Published

Daywitt, W.C., and Counas, G.J., **Measuring Adapter Efficiency Using a Sliding Short Circuit**, IEEE Transactions on Microwave Theory and Techniques, Vol. 38, No. 3, pp. 231-237 (March 1990).

This paper describes a simple technique for measuring the efficiency of low-loss adapters that is useful in microwave applications where a few hundredths of a decibel error is acceptable. An expression for the efficiency error is given.

[Contact: William C. Daywitt, (303) 497-3720]

Electro-Optic Metrology

Released for Publication

Deeter, M.N., Rose, A.H., and Day, G.W., **High-Speed, High-Sensitivity Magnetic Field Sensors Based on the Faraday Effect in YIG**.

Magnetic field sensors based on the Faraday effect in ferrimagnetic iron garnets are characterized in terms of their sensitivity, speed, and directionality. Sensitivity measurements at 80 Hz on small (e.g. 5-mm diameter x 3-mm long) samples of yttrium iron garnet (YIG) yield noise equivalent magnetic fields of 10 nT/Hz. Frequency response measurements exhibit virtually flat response to approximately 700 MHz.

[Contact: Merritt N. Deeter, (303) 497-5400]

Obarski, G.E., **A Wavelength Standard for Optical Communications**, to be published as an NIST Technical Note.

A wavelength standard in the form of a lambdameter is described for measurement of single-mode sources used in optical

Electro-Optic Metrology (cont'd.)

fiber communications. The sources of interest are mainly diode lasers emitting at 1.3 and 1.5 μm , but the system can be used in the near IR and red regions of the spectrum. Accuracy in wavelength measurement is verified to be <0.1 ppm at the 0.63- μm HeNe line by comparing separately each of two adjacent modes from a polarization-frequency-stabilized HeNe laser with a single mode from a second polarization-frequency-stabilized HeNe laser. Wavelength instability of a commercially packaged 1.52- μm distributed-feedback diode laser was measured to be in the range ± 1 ppm.

[Contact: Gregory E. Obarski, (303) 497-5747]

Parameswaran, M., Robinson, A.M., Blackburn, D.L., and Geist, J., **Micromachined Thermal and Visible Radiation Source Using a Commercial CMOS Process.**

Fabrication of a thermally isolated micromechanical structure capable of generating visible as well as thermal radiation is described. The fabrication process is completely compatible with a commercial IC process, viz., CMOS. Compatibility is achieved by providing a suitable layout for implementation by the CMOS foundry using their regular process sequence. After commercial production of the CMOS chips, a maskless dip in ethylenediamine-pyrocatechol (EDP) is performed to realize the micromechanical structure. The final device is a suspended plate structure formed out of the field oxide and the CVD oxides of the CMOS process sandwiching a pair of polysilicon resistors. A typical device under test generated a silicon weighted ($\lambda < 1.25 \mu\text{m}$) radiant intensity of 8.2×10^{12} photons/second/steradian for an input electrical power of 35 mW. The computed emittance (radiance) for the incandescent area of the device yielded an equivalent blackbody temperature of 1400 K.

[Contact: Jon Geist, (301) 975-2066]

Tang, D., Rose, A.H., and Day, G.W., **Practical Considerations in the Design of Optical Fiber Current Sensors**, to be published in the Proceedings of the International Congress on Optical Science and Engineering, The Hague, Netherlands, March 12-15, 1990.

While current sensors based on the Faraday effect in bulk materials have shown good success in field tests, the use of single-mode fiber as the sensing element has both technical and economic advantages. In this paper we describe some of the practical problems that have inhibited the development of fiber current sensors. Recent research suggests that most of these problems, including especially the problem of linear birefringence in the sensing coils, can be solved. Instruments providing a measurement quality approaching that set by fundamental materials can now be achieved.

[Contact: Dingding Tang, (301) 975-3287]

Tu, Y., Goyal, I.C., Gallawa, R.L., and Ghatak, A.K., **Solving the Scalar Wave Equation: Expansion in Terms of Hermite Gauss Functions.**

We used Hermite Gauss functions with Gelerkin's method to solve the scalar wave equation. The results are used to analyze optical waveguides, and a comparison with results obtained using trigonometric functions is presented. Our method requires fewer terms in the expansion, and it eliminates a major drawback of using the trigonometric functions.

[Contact: Robert L. Gallawa, (303) 497-3761]

Recently Published

Hickernell, R.K., Aust, J.A., and Larson, D.R., **Optical Waveguide Attenuation Measured by Photothermal Displacement**, Conference Digest of the Sixth International Topical Meeting on Photoacoustic and Photothermal Phenomena, Baltimore, Maryland, July 31-

Electro-Optic Metrology (cont'd.)

August 3, 1989, pp. 310-311 (1990).

We apply the photothermal displacement technique to the study of propagation loss in optical channel waveguides. Thermal expansion of the substrate surface due to the absorption of guided light is probed with a laser beam reflected from the surface. The technique is noncontact, has a high spatial resolution, and is applicable to a wide variety of waveguides, including packaged devices. We measure attenuation in ion-exchanged glass waveguides at a wavelength of 1.3 μm .

[Contact: Robert K. Hickernell, (303) 497-3455]

Schlager, J.B., Yamabayashi, Y., and Franzen, D.L., Recirculating Pulse Erbium-Fiber Ring Amplifier, Optical Fiber Communication Conference Technical Digest, p. 198, January 22-26, 1990.

Erbium-doped fiber amplifiers have produced up to a 34-dB optical gain at 1536 nm. Further increases in gain are accompanied by an increase in amplified spontaneous emission (ASE), which saturates the amplifier. This paper describes a gated erbium-fiber ring amplifier which avoids the problem of ASE buildup and unwanted feedback. Moreover, a large effective gain can be realized from a small single-pass gain by recirculating the pulse through the amplifier.

[Contact: John B. Schlager, (303) 497-3542]

Electromagnetic Properties

Recently Published

Geyer, R.G., Electrodynamics of Materials for Dielectric Measurement Standardization, Conference Record of the IEEE Instrumentation and Measurement Technology Conference, San Jose, California, February 13-15, 1990, pp. 2-7 (1990).

Dielectric reference materials are analyzed in light of the fundamental requirements of linearity, homogeneity, and isotropy. Generalized frequency- and temperature-dependent dispersion relations are reviewed which allow the prediction of broadband dielectric behavior from limited measurement data, determination of valid modal field structure in cavity or waveguide fixtures, and identification of discrepancies and errors in measurement data. An approach for examining the influence of deviations of sample homogeneity on a precisely specified electromagnetic field structure is outlined, and sufficient conditions for isotropic or uniaxial or biaxial anisotropic dielectric behavior are examined in terms of a material's chemical lattice physics. These characteristics direct the choices of suitable reference materials useful in dielectric metrology. Lastly, advances at the National Institute of Standards and Technology in both transmission/reflection and cavity resonator measurement techniques incorporating dielectric reference materials are noted.

[Contact: Richard G. Geyer, (303) 497-5852]

Complex Testing

Recently Published

Dai, H., and Souders, T.M., Time Domain Testing Strategies and Fault Diagnosis for Analog Systems, IEEE Transactions on Instrumentation and Measurement, Vol. 39, No. 1, pp. 157-162 (February 1990).

An efficient approach is presented for functional testing and parameter estimation of analog circuits in the time domain. The test equations are based on the sensitivity matrix, which can be obtained simultaneously with the nominal solution vector. Two examples are given, with results based on actual measurement data. Practical considerations, including the effects of ambiguity groups, measurement errors,

Complex Testing (cont'd.)

and time skew are covered. The approach can be directly extended to nonlinear circuits.

[Contact: T. Michael Souders, (301) 975-2406]

Other Fast Signal Topics

Released for Publication

Bell, B.A., Perrey, A.G., and Treado, M.J., **Evaluation of Hands-Free Communication Systems**, to be published as NISTIR 90-4230.

Hands-Free Communication Systems (HFCS) are used by law enforcement agencies, fire departments, rescue squads, and the Armed Forces, where tasks require the communications operator's hands to be free. Four such HFCSs were tested to measure their operational characteristics of voltage gain/frequency response, signal-to-noise ratio, total harmonic distortion, and sensitivity.

[Contact: Barry A. Bell, (301) 975-2402]

Capobianco, T.E., Splett, J., and Iyer, H., **Relationship of Coil Construction to Eddy Current Probe Sensitivity for Single-Coil Ferrite Core Probes**.

We report the results of the first phase of a study designed to quantify the relationship between eddy current coil construction and the performance of these coils used in nondestructive evaluation inspections. The ferrite core coils wound for this study are small but typical of the sizes commonly used in commercially manufactured eddy current probes. Coil diameters range from 1 mm to 7 mm with lengths of 0.5 mm to 4 mm. Seven parameters were studied and included: ferrite diameter, ferrite permeability, coil aspect ratio, number of turns, distance of the windings from the inspection end of the ferrite, wire gauge, and length of the ferrite beyond the end of the windings. Additionally, the coil set was designed to provide

some indication of the repeatability of identical constructions, what we have called winding inhomogeneity. The coils were incorporated into surface probes for scanning defects in flat plate specimens. The measure of sensitivity was the change of probe impedance (ΔZ) as the probe was scanned from an unflawed area to the flawed area of the test specimen. Measurements were also made of the component of ΔZ perpendicular to the liftoff vector ($\Delta Z(\perp)$).

[Contact: Thomas E. Capobianco, (303) 497-3141]

Recently Published

Fickett, F.R., and Capobianco, T.E., **Standard Reference Materials for Eddy Current Nondestructive Evaluation: Research Material 8458**, Proceedings of the Measurement Science Conference, Anaheim, California, February 8-9, 1990, unpagd.

Eddy current nondestructive evaluation is widely used in the world of transportation, and especially in evaluation of the structural integrity of aircraft. Small cracks, subsurface cracks, and cracks forming in places where access is difficult, such as bolt holes, can only be detected in the field by the use of electromagnetic methods. A large number of commercial instruments and their associated probes are available for this purpose. For optimum performance, these instruments must be calibrated. This is usually accomplished by measuring artificial flaws in the form of drill holes, spark-cut notches, or saw slots of varying dimensions in aluminum alloy plates. The problem with such calibrations is that these "standard" flaws bear little resemblance to an actual fatigue crack. Here we discuss the present situation in this field and describe research now underway at NIST to develop flaw Standard Reference Materials and Research Materials (RM) that more closely approximate the behavior of actual fatigue cracks. In particular, we will concentrate on a recently-issued RM (#8458) which is a

Other Fast Signal Topics (cont'd.)

prototype of such a crack standard.

[Contact: Fred R. Fickett, (303) 497-3785]

Kahaner, D.K., and Anderson, W.E., **VolksGrapher: A Fortran Plotting Package User's Guide, Version 3.0**, NISTIR 90-4238 (February 1990).

VolksGrapher is a FORTRAN callable library which permits users to create plots with minimum overhead. VolksGrapher originally written for PCs has also been ported to the Sun, VAX, and Convex. The plots can be viewed on the PC screen, on a SunView graphics window, or with Tektronix 4014 emulation software. Plots may be changed interactively. Modifications permitted include zooming, adding or changing text, translating and rotating text, changing page layout, axis scaling (e.g., linear to logarithmic), and axis limits. Hard copy of the plots can be in either PostScript, Tektronix, HPGL, or QMS format.

[Contact: William E. Anderson, (301) 975-2423]

Treado, M.J., Eliason, L.K., and Fulcomer, P.M., **Miniature Surveillance Recorders**, U.S. Department of Justice, National Institute of Justice, Technology Assessment, NIJ Standard-0226.00 (January 1990).

This standard is a technical document that specifies performance and other requirements equipment should meet to satisfy the needs of criminal justice agencies for high-quality service. Purchasers can use the test methods described in this standard to determine whether a particular piece of equipment meets the essential requirements, or they may have the tests conducted on their behalf by a qualified testing laboratory. Procurement officials may also refer to this standard in their purchasing documents and require that equipment offered for purchase meet the requirements. Compliance with the

requirements of the standard may be attested to by an independent laboratory or guaranteed by the vendor.

Because this NIJ standard is designed as a procurement aid, it is necessarily highly technical. For those who seek general guidance concerning the selection and application of law enforcement equipment, user guides have also been published. The guides explain in nontechnical language how to select equipment capable of the performance required by an agency.

[Contact: P. Michael Fulcomer, (301) 975-2407]

ELECTRICAL SYSTEMS

Power Systems Metrology

Released for Publication

Martzloff, F.D., **The Need for Power Quality Testing Standards**, to be published in the Proceedings of the Second National Power Quality Conference for End-Use Applications, San Francisco, California, March 22, 1990.

The quality of the power supplied to sensitive electronic equipment is an important issue. Quantifying this quality, however, is difficult under the present state of nonexistent or uncoordinated standards. Improvements in the situation described as "poor power quality" can be achieved by reducing the sensitivity of equipment to power line disturbances, or by limiting the injection of disturbances. While these remedies might seem obvious in principle, their implementation appears more difficult. Voluntary standards provide a guide for such an implementation. The formation by IEEE of a Standards Coordinating Committee on Power Quality responds to this need.

[Contact: Francois D. Martzloff, (301) 975-2409]

Martzloff, F.D., **Transient Suppression for Computer-Based Systems**.

Power Systems Metrology (cont'd.)

Computers have emigrated from the sheltered life of computer rooms to the tougher environment of offices, factories, and homes where they encounter interfering or damaging transients. The article outlines general causes and remedies, and how to deal with surges and maintain the integrity of a small computer system. Small computer systems, especially the stand-alone type, can be protected in a do-it-yourself mode. More complex systems may need the help of a specialist. Two case histories illustrate the problems and solutions; steps required to determine protection needs are described, with generic guidance on selecting an appropriate protective device.

[Contact: Francois D. Martzloff, (301) 975-2409]

Olthoff, J.K., Van Brunt, R.J., Herron, J.T., Sauers, I., and Harman, G., **Catalytic Decomposition of S_2F_{10} and Its Implications on Sampling and Detection from SF_6 -Insulated Equipment**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

Recent findings indicate that S_2F_{10} is unstable with respect to decomposition on a surface. This paper reports the first results of a study investigating the mechanisms and rates of surface decomposition of S_2F_{10} under various conditions. Initial results indicate that surface decomposition rates on stainless steel increase with increased water content, temperature, and surface-to-volume ration, and with decreased gas pressure. The implications of these results for the preparation and storage of S_2F_{10} samples are discussed. Additionally, the use of this surface decomposition mechanism to enhance the detection sensitivity of small concentrations of S_2F_{10} in SF_6 using a gas chromatograph/mass spectrometer is investigated. Detection sensitivities

of 1 ppm_v of S_2F_{10} in SF_6 are routinely achievable using this new technique.

[Contact: James K. Olthoff, (301) 975-2431]

Ramboz, J.D., Fenimore, C., and Schiller, S.B., **Qualifying Watthour Meters for Use as MAP Transport Standards**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

The NIST Measurement Assurance Program (MAP) transfers the watthour using transport meters. A statistical design is employed to determine the linear and nonlinear corrections for the response of each meter to varying conditions of voltage, current, temperature, and power factor. For applications requiring lower precision, a heuristic for dropping correction terms is given.

[Contact: John D. Ramboz, (301) 975-2434]

Ramboz, J.D., and West, J.L., **Watt Transfer Standard**, to be published in the Digest of the 1990 Conference on Precision Electromagnetic Measurements, Ottawa, Canada, June 11-14, 1990.

The use of a time-division multiplier power meter as a watt transfer standard between the National Institute of Standards and Technology (NIST) and an industry standards laboratory is described. Measurements of power at 120 and 240 V, 5 A, 50 and 62 Hz, and power factors of 1 and 0 lagging. After the unit of power was transferred to the industrial laboratory, a comparison of the laboratory and NIST calibrations indicated an agreement to within 14 parts per million.

[Contact: John D. Ramboz, (301) 975-2434]

Steiner, J.P., and Martzloff, F.D., **Partial Discharge in Low Voltage Cables**, to be published in the Proceedings of the 1990 IEEE International Symposium on Electrical Insulation,

Power Systems Metrology (cont'd.)

Toronto, Ontario, Canada, June 3-6, 1990.

Testing of high-voltage apparatus for partial discharge has long been recognized as an important part of quality control for these devices. Recently, interest has been focused on methods for testing low-voltage cables to determine their integrity under adverse operating conditions. A new method, utilizing partial discharge, is presented which has the potential for locating breaches in the insulation of in-situ, low-voltage, multi-conductor cables.

[Contact: Francois D. Martzloff, (301) 975-2409]

Recently Published

Martzloff, F.D., and Gruzs, T.M., **Monitoring Power Quality**, Powertechnics Magazine, Vol. 6, No. 2, pp. 22-26 (February 1990).

The quality of the power supplied to sensitive electronic equipment is an important issue. Monitoring disturbances of the power supply has been the objective of various site surveys, but results often appear to be instrument-dependent or site-dependent, making comparisons difficult.

[Contact: Francois D. Martzloff, (301) 975-2409]

Martzloff, F.D., and Gruzs, T.M., **Systems and Instruments in Site Surveys**, Powertechnics Magazine, Vol. 6, No. 3, pp. 34-39 (March 1990).

Every on-site survey of power quality utilizes a variety of methods and instruments, requiring careful interpretation of survey results. A close examination of underlying assumptions in nine published surveys shows that some differences can be reconciled, but indicates the need for standards.

[Contact: Francois D. Martzloff, (301) 975-2409]

Van Brunt, R.J., **Processes Leading to SF₆ Decomposition in Glow-Type Corona Discharges**, The Physics of Ionized Gases (SPIG '88), pp. 161-172, (Nova Science Publishers, Inc., Commack, New York, 1989) [Proceedings of the 14th Summer School and International Symposium on the Physics of Ionized Gases, Sarajevo, Yugoslavia, August 15-19, 1988.]

Recent progress which has been made in understanding the fundamental gas-phase oxidation processes involving SF₆ in corona discharges is discussed here within the framework of a three-zone chemical kinetics model. Gaps in our knowledge about fundamental molecular interactions that are keys to a better understanding of SF₆ oxidation are discussed.

[Contact: Richard J. Van Brunt, (301) 975-2425]

Van Brunt, R.J., and Herron, J.T., **Fundamental Processes of SF₆ Decomposition and Oxidation in Glow and Corona Discharges**, IEEE Transactions on Electrical Insulation, Vol. 25, No. 1, pp. 75-94 (February 1990).

The current state of our knowledge about the fundamental collision processes involving electrons, ions, free radicals, and molecules needed to understand the gas-phase discharge chemistry in SF₆ is reviewed. It is shown that the electron-impact dissociation of SF₆ leading to reactive neutral fragments is the decomposition rate controlling factor in corona and glow discharges. Data on electron-impact cross sections for SF₆ are reviewed and used to compute SF₆ dissociation rates as functions of E/N for mixtures of SF₆ with O₂ and H₂O. The calculated and measured rates for subsequent gas-phase reactions involving the lower valence sulfur fluorides (SF_x, x < 6) and other reactive species like OH and O are also reviewed. The temperature and E/N dependencies of rates for F⁻ transfer reactions of SF₆ with SOF₄, SO₂, SiF₄, and other species generated by

Power Systems Metrology (cont'd.)

discharge-induced oxidation of SF_6 are reviewed together with data on collisional electron detachment and ion conversion processes involving interactions of F^- , SF_5^- , and SF_6^- with SF_6 . The relevance of these negative-ion molecule interactions to ion transport and oxidation rates in SF_6 is discussed. Rates for various slow gas-phase hydrolysis processes that can affect observed relative yields of oxidation by-products are also considered. Implications of the fundamental rate data reviewed here to recently proposed chemical kinetics models of corona and glow-type discharges in SF_6 are discussed.

[Contact: Richard J. Van Brunt, (301) 975-2425]

Superconductors

Released for Publication

Goodrich, L.F., and Bray, S.L., **High- T_c Superconductors and the Critical-Current Measurement.**

With the introduction of high- T_c superconductors, a number of problems associated with the critical-current (I_c) measurement has arisen. The existing I_c measurement practices have been developed and proven for low- T_c superconductors. There are substantial differences between the two classes of materials. When the I_c concept was casually extended to the high- T_c conductors, the problems of measurement inconsistency, ambiguity, and in some cases, invalidity followed. A discussion of the underlying philosophy of the I_c measurement is presented. Also, a number of measurement variables that can influence the measured I_c are discussed. Many of the problems stem from inadequate I_c reporting practices. Recommendations are given for improving I_c measurement reports.

[Contact: Loren F. Goodrich, (303) 497-3143]

Tan, Z., Filipkowski, M.E., Budnick, J.I., Heller, E.K., Brewe, D.L., Chamberland, B.L., Bouldin, C.E., and Woicik, J.C., **Strontium-Induced Oxygen Defect Structure and Hole Doping in $\text{La}_{2-x}\text{Sr}_x\text{CuO}_4$.**

We have discovered that the apical oxygen with the shortest La-O bond length is removed when La is substituted by Sr in polycrystalline $\text{La}_{2-x}\text{Sr}_x\text{CuO}_4$ under normal preparation conditions. It is reasoned that this missing oxygen is relocated at a defect site in the vicinity of the Sr dopant. We present evidence that this defect oxygen is intrinsic to Sr doping independent of processing conditions. A range of physical properties of $\text{La}_{2-x}\text{Sr}_x\text{CuO}_4$ can be understood in terms of this Sr-induced defect oxygen and the proposed role of hole doping through this defect oxygen.

[Contact: Charles E. Bouldin, (301) 975-2046]

Recently Published

Ekin, J.W., **Ohmic Contacts to High- T_c Superconductors**, Proceedings of SPIE (The International Society for Optical Engineering, P.O. Box 10, Bellingham, Washington 98227), Vol. 1187, Processing of Films for High T_c Superconducting Electronics, pp. 359-364 (1989).

This note summarizes and gives references describing the details of a method for reducing high T_c contact surface resistivities, ρ_c , to the $10^{-10} \Omega \text{ cm}^2$ range ($\rho_c \equiv RA$, where R is the contact resistance and A is the contact area). The reduction was obtained using both gold and silver contacts, and represents a decrease in contact resistivity by over eight orders of magnitude from that obtained using indium solder connections. We have obtained most of the results so far for $\text{YBa}_2\text{Cu}_3\text{O}_{7-\delta}$ (YBCO) but preliminary data for the Bi and Tl based compounds are also summarized.

[Contact: Jack W. Ekin, (303) 497-5448]

Superconductors (cont'd.)

Ekin, J.W., Peterson, R.L., and Bray, S.L., **Critical Currents of High- T_c Superconductors: Pinning, Weak Links, Conduction Anisotropy, and Contact Resistivities** [original title: Effect of Small Coherence Length on the Critical Current of High- T_c Superconductors: Pinning, Weak Links, Conduction Anisotropy, and Contact Resistivities], Proceedings of the Materials Research Society International Meeting on Advanced Materials, Tokyo, Japan, 1988, Vol. 6, pp. 135-144 (1989).

The coherence length ξ of high- T_c superconductors is about an order of magnitude smaller than for conventional superconductors. This intrinsic difference has profound consequences for the transport properties of high- T_c superconductors. Because the pinning effectiveness of defects of average size $\langle D \rangle$ is greatest for $\langle D \rangle / \xi = 1$ and decreases rapidly for $\langle D \rangle / \xi < 1$, atomic scale defects are ineffective as pinning sites in conventional superconductors, but play an important role in high- T_c superconductors. Unfortunately, the small coherence length also makes atomic scale defects effective tunneling barriers in high- T_c superconductors. Thus, from the practical standpoint of producing high transport critical current J_c in high- T_c superconductors, the conventional problem of pinning force enhancement is replaced by weak-link minimization. The transport J_c is nearly independent of the angle between the applied magnetic field and the average transport current direction, indicating highly convoluted percolation paths in these materials. Conduction anisotropy is a secondary factor, but emerges as a prime determinant of transport J_c in the absence of weak link effects. The effect of conduction anisotropy on transport J_c is described in terms of a current-transfer model. A method used to achieve contact resistivities in the 10^{-10} $\Omega\text{-cm}^2$ range is summarized.

[Contact: John W. Ekin, (303) 497-5448]

Goodrich, L.F., Goldfarb, R.B., and Bray, S.L., **Development of Standards for Superconductors Final Report, January 1988 - December 1989**, NISTIR 90-3935 (January 1990).

A cooperative program with the Department of Energy, the National Institute of Standards and Technology, other national laboratories, and private industry is in progress to develop standard measurement practices for use in large-scale applications of superconductivity. This report describes research for the period January 1988 through December 1989. It contains the results of critical current studies on a large conductor Reference Material, the effect of power-supply current ripple, the measurements of large conductors, and an interlaboratory comparison (round robin) of Nb_3Sn wires. Short-range variations in magnetic hysteresis loss in multifilamentary Nb_3Sn were studied. The results of participation in several interlaboratory comparisons are described.

[Contact: Loren F. Goodrich, (303) 497-3143]

Magnetic Materials & Measurements

Released for Publication

Deeter, M.N., Rose, A.H., and Day, G.W., **High Speed Magnetic Field Sensors Based on Iron Garnets**, to be published in the Proceedings of the Department of Defense Fiber Optics Conference '90, McLean, Virginia, March 20-23, 1990.

We characterize magnetic field sensors based on the Faraday effect in ferrimagnetic iron garnets in terms of their sensitivity and frequency response. Signal-to-noise measurements at 80 Hz on a sample of yttrium iron garnet yield noise equivalent magnetic fields of 10 nT/Hz. Frequency response measurements exhibit virtually flat response to approximately 700 MHz.

Magnetic Materials & Meas. (cont'd.)

[Contact: Merritt N. Deeter, (303) 497-5400]

Moreland, J., and Rice, P., **High Resolution Tunneling Stabilized Magnetic Imaging and Recording.**

A scanning tunneling microscope (STM) has been used to image and record magnetic regions on the surface of a computer hard disk. The usual rigid STM tip was replaced by a compliant magnetized Fe film tip. As a result, tunneling images were combinations of the surface topography and variations in the magnetic force between the Fe film tip and the disk surface. We believe that the recording process relied on maintaining the close proximity of a magnetized Fe film tip near the disk surface. Apparently, the magnetic field was focused near the Fe film tip with sufficient intensity to change the surface magnetization of the disk. We have recorded spots on the disk within a $500 \times 500 \text{ nm}^2$ area. These spots were subsequently imaged with the same STM tip. Our best magnetic image resolution was 20 nm. The compliance of the Fe film tips was such that image contrast due to variation of the magnetic force on the Fe film tip corresponded to z-motion piezoelectric elongations as large as 50 nm.

[Contact: John Moreland, (303) 497-3641]

Other Electrical Systems Topics

Recently Published

Martzloff, F.D., **A Review of Candidate Methods for Detecting Incipient Defects Due to Aging of Installed Cables in Nuclear Power Plants**, Proceedings of the Workshop on Power Plant Cable Condition Monitoring, San Francisco, California, February 16-18, 1988, pp. 25-1 to 25-11 (July 1988) [also published as NBSIR 88-3774 (May 1988)].

Several types of test methods have been

proposed for detecting incipient defects due to aging in cable insulation systems, none offering certainty of detecting all possible types of defects. Some methods constitute direct detection of a defect in the cable; other methods detect changes in electrical or non-electrical parameters from which inferences can be drawn on the integrity of the cable. The paper summarizes the first year of a program conducted at the National Bureau of Standards to assess the potential of success for in-situ detection of incipient defects by the most promising of these methods.

[Contact: Francois D. Martzloff, (301) 975-2409]

ELECTROMAGNETIC INTERFERENCE

Radiated Electromagnetic Interference

Recently Published

Kanda, M., **A Microstrip Patch Antenna as a Standard Transmitting and Receiving Antenna**, IEEE Transactions on Electromagnetic Compatibility, Vol. 32, No. 1, pp. 5-8 (February 1990), [also published in the Digest of the International Symposium on Electromagnetic Metrology (ISEM '89), Beijing, China, August 16-19, 1989.]

This paper discusses the possibility of employing a microstrip patch antenna as a standard transmitting antenna. The intrinsic properties of the substrate used for the antenna are determined by careful impedance measurements. The experimental results indicate that the transmitting characteristics of a microstrip antenna can be theoretically determined from its geometry. The microstrip patch antenna discussed here is physically small (20-cm square for 450 MHz) and can be well matched to a power delivery system (standing-wave ratio = 1.17).

[Contact: Motohisa Kanda, (303) 497-5320]

Wu, D.I., and Kanda, M., **Comparison of Theoretical and Experimental Data for**

Radiated EMI (cont'd.)

the Near Field of an Open-Ended Rectangular Waveguide, IEEE Transactions on Electromagnetic Compatibility, Vol. 31, No. 4, pp. 353-358 (November 1989).

A comparison between theoretical and experimental data on the radiating near field of an open-ended waveguide (OEG) is presented. Two theoretical methods are examined. The first one is an approximation based on simple plane wave equations with the electric field expressed in terms of the gain of the OEG. The gain equation is an empirical equation obtained from scaled measured data. The second approach is based on far-field-to-near-field transformations. Its purpose is to provide an alternate method for computing the fields as well as to provide a means of assessing the accuracy of the first approach. Theoretical data computed using both methods are presented along with measured data obtained in the anechoic chamber. The discrepancy between the two theoretical approaches is typically less than 0.5 dB (while the discrepancy between the theoretical and experimental results is small) and increases with the distance between the OEG and the field point.

[Contact: Motohisa Kanda, (303) 497-5320]

Conducted Electromagnetic Interference

Recently Published

Martzloff, F.D., and Leedy, T.F., Electrical Fast Transient Tests: Applications and Limitations, Conference Record of the IEEE Industry Applications Society Annual Meeting, Part II, San Diego, California, October 1-5, 1989, pp. 1625-1632 (October 1989) [also published in the Proceedings of the IEEE Industrial Applications Society 35th Annual Petroleum & Chemical Industry Conference, Dallas, Texas, September 12, 1988, pp. 1-8 (1988)].

The Technical Committee TC 65 of the International Electrotechnical Commission (IEC) has promulgated a new document (IEC 801-4) requiring demonstration of the immunity of industrial process control equipment to fast transients occurring in power and data lines. These fast transients contain high-frequency components, intuitively expected to suffer greater attenuation than the lower-frequency components as they propagate along the lines. Quantifying this intuitive expectation provides a perspective on the severity of the situation and helps in defining realistic test requirements. To that end, this paper describes specific measurements conducted for typical low-voltage power line configurations; modeling of the attenuation provides a tool for understanding the significance of the line parameters and extends the usefulness of results to general cases. [Contact: Francois D. Martzloff, (301) 975-2409]

ADDITIONAL INFORMATION

Lists of Publications

Lyons, R.M., and Gibson, K.A., A Bibliography of the NIST Electromagnetic Fields Division Publications, NISTIR 89-3920 (September 1989).

This bibliography lists publications by the staff of the National Institute of Standards and Technology's Electromagnetic Fields Division for the period from January 1970 through August 1989. Selected earlier publications from the Division's predecessor organizations are included.

[Contact: Kathryn A. Gibson, (303) 497-3132]

DeWeese, M.E., Metrology for Electromagnetic Technology: A Bibliography of NIST Publications, NISTIR 89-3921 (August 1989).

This bibliography lists the publications of the personnel of the Electromagnetic Technology Division of NIST in the

Additional Information (cont'd.)

period from January 1970 through publication of this report. A few earlier references that are directly related to the present work of the Division are included.

[Contact: Sarabeth Moynihan, (303) 497-3678]

Palla, J.C., and Meiselman, B., **Electrical and Electronic Metrology: A Bibliography of NIST Electricity Division's Publications**, NIST List of Publications 94 (January 1990).

This bibliography covers publications of the Electricity Division, Center for Electronics and Electrical Engineering, NIST, and of its predecessor sections for the period January 1968 to December 1989. A brief description of the Division's technical program is given in the introduction.

[Contact: Jenny C. Palla, (301) 975-2220]

Walters, E.J., **Semiconductor Measurement Technology**, NBS List of Publications 72 [a bibliography of NBS publications concerning semiconductor measurement technology for the years 1962-1989] (March 1990).

This bibliography contains reports of work performed at the National Institute of Standards and Technology in the field of Semiconductor Measurement Technology in the period from 1962 through December 1989. An index by topic area and a list of authors are provided.

[Contact: E. Jane Walters, (301) 975-2050]

NEW CALIBRATION SERVICES OFFERED

The explosive growth of optical fiber use in the communications industry has resulted in a demand for calibration services. NIST's Boulder, Colorado, laboratory now offers **measurements of optical laser power and energy at wavelengths and power levels of interest to fiber optic producers and users.**

Measurements are based on a standard reference instrument called the C-series calorimeter. An electrically calibrated pyroelectric radiometer (ECPR) is calibrated against the calorimeter and is then used to calibrate optical power meters at wavelengths of 850, 1300, and 1550 nm. To improve calibration capabilities, NIST is preparing test measurement systems for detector linearity, detector uniformity, and detector spectral responsivity. These systems should be available in 6 months. For a paper outlining NIST's optical power measurement capabilities, contact Fred McGehan, Div. 360, NIST, 325 Broadway, Boulder, Colorado 80303. For more information on calibration services, contact Thomas R. Scott, Div. 724, same address, or phone (303) 497-3651.

NEW NIST RESEARCH MATERIAL

NIST has announced the availability of **Research Material 8458**, a well-characterized artificial flaw used as an **artifact standard in eddy current nondestructive evaluation (NDE)**. The new Research Material (RM) is the outcome of work carried out by the Division to address the need for calibration standards for eddy-current NDE, for example as used to detect fatigue cracks in aircraft structures. The RM flaw is produced in an annealed aluminum alloy block by first indenting the block and then compressively deforming the resulting notch until it is tightly closed. The next operation is to restore a flat finish to the block face, after which the block is heat treated to the original temper. The controlled flaw has been named the "CDF notch," after its inventors (listed on patent application) Thomas E. Capobianco (Electromagnetic Technology Division), William P. Dube (Division 583), and Ken Fizer (Naval Aviation Depot, NAS Norfolk, Virginia).

In the past, the challenge has been to manufacture artificial flaws that closely simulate the mechanical

New NIST Research Material (cont'd.)

properties of fatigue cracks. Currently used artifacts include electrical-discharge-machined and saw-cut notches, both of which are relatively poor representations of fatigue cracks as their widths are too great. The Division-developed method provides notches that can be made controllably in a variety of geometries, have known dimensions, with widths that are narrow enough to provide an acceptable representation of fatigue cracks.

An NIST Research Material is not certified by NIST, but meets the International Standards Organization definition of "a material or substance one or more properties of which are sufficiently well established to be used in the calibration of an apparatus, the assessment of a measurement method, or for assigning values to materials." The documentation issued with RM 8458 is a "Report of Investigation." Contact: technical information -- Fred Fickett, (303) 497-3785; order information-- Office of Standard Reference Materials, (301) 975-6776.

JAN. 1, 1990 CHANGES IN THE U.S. ELECTRICAL UNITS

Effective January 1, 1990, the U.S. as-maintained (i.e., "practical") units of voltage and resistance were increased by 9.264 ppm and 1.69 ppm, respectively. The increases in the U.S. legal units of current and of electrical power will be about 7.57 ppm and 16.84 ppm, respectively. These changes result from efforts by the major national standardizing laboratories, including the National Institute of Standards and Technology (NIST), formerly the National Bureau of Standards (NBS), to re-evaluate their as-maintained units in terms of the International System of Units (SI). The consequence of this activity has been the introduction of standards representing the SI units of voltage and resistance by the International Committee of Weights and

Measures, an international body created by the Treaty of the Meter.¹ The use of these standards world-wide beginning January 1, 1990, will result in international consistency of electrical measurement as well as coherence among the practical units of length, mass, electricity, time, etc., inherent in the definitions of the SI.

Implementation of Changes at NIST

These changes have been instituted in the U.S. by NIST using the new, internationally-adopted constants $K_{J-90} = 483\,597.9\text{ GHz/V}$ exactly and $R_{K-90} = 25\,812.807\ \Omega$ exactly with the Josephson and quantum Hall effects to establish representations of the SI volt and ohm, respectively. The representation of the SI volt is attained by using K_{J-90} in the formula

$$U_J(n) = \frac{f}{K_J} \quad n = 1, 2, 3, \dots$$

to give the voltages $U_J(n)$ of the steps produced by the ac Josephson effect at a frequency f . The past value, K_{J-72} , was $483\,593.42\text{ GHz/V(NBS-72)}$, thus leading to the 9.264 ppm change. Likewise, R_{K-90} is used in the following formula for the resistance of the i^{th} plateau of a quantum Hall effect device,

$$R_H(i) = \frac{R_K}{i} \quad (R_K = R_H(1))$$

to realize a representation of the SI ohm. The most recent past national unit of resistance, $\Omega(\text{NBS-48})_t$, was based on a group of five Thomas one-ohm standards and had an uncompensated drift rate of approximately -0.053 ppm per year.

¹Note that the SI Units have not been redefined; rather, they have been realized more accurately and a quantum physics representation of the ohm has been introduced, thus leading to the changes in magnitude of the practical or as-maintained units.

Changes in U.S. Elec. Units (cont'd.)

Since the quantum Hall effect is used as the national standard, the U.S. representation of the ohm has no drift. (The past unit of voltage, V(NBS-72), was based on the Josephson effect since 1972, and accordingly had a zero drift rate.)

Reassignments to Non-adjustable Standards

Since the U.S. practical volt and ohm units increased on January 1, 1990, the changes must be implemented in non-adjustable standards calibrated in terms of V(NBS-72) and/or Ω (NBS-48) only by reducing the values assigned to them proportionally. The examples given below show how to do this for a standard cell and a standard resistor.

Sample Adjustments of Values of Standards

Standard cell:

"Old" emf 1.0180564 V(NBS-72)

Multiply "Old" emf by 0.999990736 to get emf in terms of the present volt representation $1.01804697 \approx 1.0180470$ V

Standard resistor:

"Old" resistance value
9999.976 Ω (NBS-48)_{01/01/90}

Multiply "Old" resistance by 0.99999831 to get the resistance in terms of the present ohm representation
 $9999.9591 \approx 9999.959$ Ω

In the above, "Old" refers to the value of the standard which would have been in use on January 1, 1990, had the changes not been made; i.e., if a correction curve based on its past assigned values has been employed to obtain the currently-used value for a standard, the above represents a downward shift of the curve starting January 1, 1990. For resistance, the slope of the curve also

changed (slightly) since Ω (NBS-48) has a drift rate and Ω (NIST-90) does not.

Do not send your standards to NIST for recalibration on January 1, 1990, unless they are normally due then. The changes are accurately known and corrections to existing standards may be applied.

Adjustment of Instrumentation

An assigned or calibrated value of a standard is merely a label giving the magnitude of the parameter embodied in the standard. The actual emf or resistance of a standard did not change on January 1, 1990; only what it is called should have changed. In the same sense, meter readings are labels giving the magnitudes of the parameters being measured. **Readings taken after January 1, 1990 using unadjusted meters will be too large in magnitude.** Adjustments to meters must have the effect of reducing the amplitudes of readings for fixed emf's or resistances.

Adjustable voltage and current sources or adjustable resistors for which nominal output is desired, on the other hand, must have their outputs **increased** proportionally by the above amounts. DVM calibrators are probably the largest class of this type of instrument.

Guidelines

The National Conference of Standards Laboratories (NCSL) and NIST have formed NCSL ad hoc Committee 91.4, Changes in the Volt and Ohm to assist industry and government laboratories in coming into compliance with the changes. A major responsibility of the committee is the generation and publication of a set of guidelines which describes unambiguous methods for adjusting standards and instruments, or their values, and delineates other types of problems which may arise, e.g., voltage values called out explicitly in maintenance procedures, values imbedded in software, and the like. These guidelines have been published as NIST Technical Note 1263,

Changes in U.S. Elec. Units (cont'd.)

"Guidelines for Implementing the New Representations of the Volt and Ohm Effective January 1, 1990." This document is available at no charge through the NIST Electricity Division. To receive a copy, contact Sharon Fromm at 301-975-4222.

For further information, contact Norman B. Belecki (301-975-4223), Ronald F. Dziuba (301-975-4239), Bruce F. Field (301-975-4230), or Barry N. Taylor (301-975-4220).

U.S. REPRESENTATIONS OF ELECTRICAL POWER AND ENERGY

Watt, Var, Volt-Ampere
Joule, Watthour, Varhour
Volt-Ampere-hour, and Q-hour

Background

By international agreement, starting on January 1, 1990, the U.S. put into place new representations of the volt and ohm based, respectively, on the Josephson and Quantum Hall effects and which are highly consistent with the International Systems of Units (SI). Implementation of the new volt and ohm representations in the U.S. required that on January 1, 1990, the value of the present national volt representation maintained by the National Institute of Standards and Technology (NIST, formerly the National Bureau of Standards) be increased by 9.264 parts per million (ppm) and that the value of the national ohm representation be increased by 1.69 ppm (1 ppm = 0.0001%). The resulting increase in the national representation of the ampere is 7.57 ppm. The resulting increase in the national representations of the electrical quantities of power, namely the watt, var, and volt-ampere, and the quantities of energy, namely the joule, watthour, varhour, volt-ampere-hour, and Q-hour is 16.84 ppm.

The adjustment for electrical power and energy is generally very small compared

to revenue metering measurement uncertainties (typically greater than $\pm 0.1\%$) and therefore are not likely to have a significant effect. Adjustments do not need to be applied in the above instances. However, for the highest accuracy calibrations of power and energy standards having uncertainties less than $\pm 0.020\%$, adjustments should be made. Accordingly, all Reports of Calibration and Reports of Test issued by NIST after January 1, 1990, reflect the appropriate changes.

For instruments calibrated prior to January 1, 1990, adjustments to the calibration values due to the change in the volt and ohm can be made without instrument recalibration. The adjustments are exact and, if properly applied, will not introduce any errors. Examples given below will illustrate proper procedures for applying the new adjustments.

Adjustments for Wattmeters, Varmeters, and Volt-Ampere Meters

Calibrations of wattmeters, varmeters, and volt-ampere meters at NIST provide customers with corrections and uncertainties given in units of watts, vars, or volt-amperes, as appropriate. Applying the appropriate adjustment due to the new representations of the volt and ohm for power measuring instruments (i.e., wattmeters for "real power" and varmeters for quadrature or imaginary power) requires minor calculations. First, it is necessary to assess the magnitude of the calibration uncertainty in percent and then decide if applying adjustments for the change in the volt and ohm are required. To determine the percentage uncertainty, simply divide the uncertainty in watts, vars, or volt-amperes by the product of the applied voltage and current times the power factor (the real power) and multiply that quantity by 100, as

$$U\% = [(U_w, U_v, \text{ or } U_{va}) / (V_a \times I_a \times PF)] \times 100,$$

Electrical Power & Energy (cont'd.)

$$0.000017 = 0.010 \text{ watts.}$$

where

U% is the uncertainty in percent,
 U_w is the calibration uncertainty in watts,
 U_v is the calibration uncertainty in vars,
 V_{va} is the calibration uncertainty in volt-amperes,
 V_a is the applied voltage in volts,
 I_a is the applied current in amperes, and
 PF is the power factor (including its sign).

For example, if the uncertainty is stated on a Report of Calibration as ± 0.060 watts for the calibration of a wattmeter at an applied voltage of 120 V and an applied current of 5 A at unity power factor, then

$$\begin{aligned} \text{Percent Uncertainty} = U\% &= [(\pm 0.060 \text{ W}) / \\ & (120 \text{ V} \times 5 \text{ A} \times 1)] \times 100 \\ &= \pm 0.010\%. \end{aligned}$$

If the percentage uncertainty, as calculated above, is less than $\pm 0.020\%$, (as it is in the above example), then it is recommended that an adjustment of 0.0017% (0.001684% rounded to four significant decimal places) due to the new representations of the volt and ohm be applied.

The second step is the calculation of how large the adjustment will be (in units of watts, vars, or volt-amperes, as appropriate), due to the reassignment of the volt and ohm. For the same example given above, if the calibration correction was given in a Report of Calibration as +0.052 watts, then the adjustment due to the change in the volt and ohm may be calculated by multiplying the product of the applied voltage and current times the power factor by 0.000017 (0.0017% expressed in proportional parts), as

$$\begin{aligned} \text{Adjustment} &= (V_a \times I_a \times \text{PF}) \times 0.000017 \\ \text{Adjustment} &= (120 \text{ V} \times 5 \text{ A} \times 1) \times \end{aligned}$$

The resulting product should be rounded to the same number of significant decimal places as the old calibration correction was given. This result is then subtracted from the old calibration correction, as in the following example:

$$\begin{aligned} \text{Old Calibration Correction} \\ (\text{prior to } 1/1/90) &= (+0.052 \text{ watts}) \\ \text{less } 0.000017 \times \text{Applied} \\ \text{Volt-amperes} \times \text{PF} &= \underline{- (+0.010 \text{ watts})} \\ \text{New Calibration Correction} \\ (\text{after } 1/1/90) &= (+0.042 \text{ watts}) \end{aligned}$$

If the old calibration correction (prior to 1/1/90) at test conditions of 120 V, 5 A, and at a power factor of 0.5 lag, happened to be a negative quantity, for example, -0.031 watts, then the old calibrations correction would be decreased (made more negative) by 0.0017% of the applied volt-ampere product times the power factor, as in the following example:

$$\begin{aligned} \text{Old Calibration Correction} \\ (\text{prior to } 1/1/90) &= (-0.031 \text{ watts}) \\ \text{less } 0.000017 \times \text{Applied} \\ \text{Volt-amperes} \times \text{PF} &= \underline{- (+0.005 \text{ watts})} \\ \text{New Calibration Correction} \\ (\text{after } 1/1/90) &= (-0.036 \text{ watts}) \end{aligned}$$

The process of making the corresponding change for the varmeter corrections is identical to that shown above. For volt-ampere meters, the adjustment is made independent of the power factor (i.e., a value of PF = 1 may be used). However, most varmeter and volt-ampere meter calibrations have stated uncertainties greater than $\pm 0.020\%$, and hence, would not require an adjustment.

Adjustments for Joule, Watt-, Var-, Volt-Ampere- and Q-Hour Meters

Applying adjustments to electric energy measuring instruments (i.e., joule, watthour, varhour, volt-ampere-hour, and Q-hour meters) for changes in the representation of the volt and ohm, is more straightforward because the common

Electrical Power & Energy (cont'd.)

calibration constant for energy metering is expressed as a "percentage registration." The amount the registration is to be adjusted can be subtracted directly as a percentage, regardless of power factor.

For example, if a watthour meter has a registration of 100.015% before January 1, 1990, then after that date, the new assigned registration would be decreased by 0.0017% (rounded from 0.001684%) as

Old percentage registration	
(prior to 1/1/90)	= 100.015%
less amount due to change	
in volt and ohm	= <u>-0.0017%</u>
New percentage registration	
(after 1/1/90)	= 100.0133%
Rounded to three significant	
decimal places	= 100.013%

The process of making the corresponding changes for the joule, varhour, volt-ampere-hour and Q-hour meters are identical to that shown above. If the associated uncertainty of the calibration is greater than $\pm 0.020\%$, no adjustments are necessary, as stated in the instances for wattmeters, varmeters, and volt-ampere meters. The uncertainties for varhour, volt-ampere-hour, and Q-hour meters are seldom less than $\pm 0.020\%$, and hence adjustments generally do not need to be made.

Reference

N. B. Belecki, R. F. Dziuba, B. F. Field, and B. N. Taylor, Guidelines for Implementing the New Representations of the Volt and Ohm Effective January 1, 1990, NIST Tech. Note 1263, June, 1989.

Copies of the above document are available at no cost from:

National Institute of Standards and Technology
Electricity Division, MET B146
Gaithersburg, MD 20899
Telephone: (301) 975-4222

For Further Information

For further information concerning the above information, contact either John D. Ramboz (301) 975-2434 or Thomas L. Nelson (310) 975-2427, or write:

National Institute of Standards and Technology
Electricity Division, MET B344
Gaithersburg, MD 20899

NEW BROCHURE FOR SEMICONDUCTOR SRMs

Standard Reference Materials for Semiconductor Manufacturing Technology lists a series of SRMs for use in characterizing semiconductor materials and processes. The SRMs include a series of silicon resistivity materials for calibrating four-probe and eddy-current test equipment, sizing materials for calibrating optical and scanning electron microscopes, SRMs for mechanical testing, optical measurements, X-ray and photographic films, X-ray diffraction, and the chemical analysis of materials.

[Contact: Roger Rensberger, (301) 975-2762]

1990 CEEE CALENDAR

September 11-12, 1990 (Boulder, CO)

Symposium on Optical Fiber Measurements. NIST, in cooperation with the Institute of Electrical and Electronics Engineers Optical Communications Committee and the Optical Society of America, will sponsor the 6th biennial Symposium on Optical Fiber Measurements. The symposium will be devoted entirely to measurements on fiber, related components, and systems. Typical topics will include telecommunications fibers, fiber lasers and amplifiers, fibers for sensors, couplers, connectors, multiplexers, integrated optics, sources, detectors, modulators, switches, long haul systems, LANs, subscriber loops, field and laboratory instrumentation, and standards. Experimental and analytical papers are solicited on any aspect of

1990 CEEE Calendar (cont'd.)

measurements for guided-lightwave technology. Those who wish to present a paper must submit a summary by May 31, 1990 to: Gordon W. Day, Program Chairman, Symposium on Optical Fiber Measurements, NIST, Div. 724.02, Boulder, Colo. 80303-3328. For more information, contact the General Chairman, Douglas L. Franzen, at the same address, or call 303/497-3346.

September 17-19, 1990 (Boston, MA)

VLSI and GaAs Chip Packaging Workshop. The IEEE CHMT Society and the National Institute of Standards and Technology are co-sponsoring the Ninth VLSI packaging Workshop. Topics to be discussed include VLSI package design; multichip module design; WSI packaging; package thermal design; package electrical design; GaAs IC packaging; VLSI package interconnection options; VLSI package materials and die-attach solutions; and failure mechanism and quality of VLSI packages. All attendees are expected to be specialists working in the field and to participate in discussions.
[Contact: George G. Harman, (301) 975-2097]

October 24-26 (Boulder, CO)

Symposium on Optical Materials for High Power Lasers (Boulder Damage Symposium). The Symposium is the principal forum for the exchange of information on the physics and technology of materials for high-power lasers. Co-sponsors in addition to NIST are ASTM -- Standards for Materials, Products, Systems & Services; the Center for Research in Electro-Optics and Lasers at the University of Central Florida; the Defense Advanced Research Projects Agency; Lawrence Livermore National Laboratory, Los Alamos National Laboratory; SPIE -- the International Society for Optical Engineering; and the

Weapons Laboratory of the U.S. Air Force. Topics on the agenda include new materials, bulk damage phenomena, surface and thin-film damage, preparation of optical material, measurement of optical material properties, design consideration for high-power systems, and fundamental mechanisms of laser-induced damage.
[Contact: Aaron A. Sanders, (303) 497-5341]

CEEE SPONSORS

National Institute of Standards and Technology
U.S. Air Force
Newark Air Force Station; Hanscom Field; Rome Air Development Center; Space & Missile Organization; U.S. Air Force Headquarters; Wright-Patterson Air Force Base
U.S. Army
Fort Belvoir; Fort Monmouth; Fort Huachuca; Materials & Mechanics Research Center; Strategic Defense Command; Dugway Proving Ground; AVRADCOM (Aviation)
Department of Defense
Advanced Research Projects Agency; Defense Communication Agency; Defense Nuclear Agency; Combined Army/Navy/Air Force (CCG)
Department of Energy
Energy Systems Research; Fusion Energy; Basic Energy Sciences; High Energy & Nuclear Physics
Department of Justice
Law Enforcement Assistance Administration
U.S. Navy
Naval Sea Systems Command; Weapons Support Center/Crane; Office of Naval Research; Naval Ship Research Development Center; Naval Air Systems Command; Aviation Logistics Center/Patuxent; Naval Explosive Ordnance Disposal Tech. Center
National Science Foundation
National Aeronautics and Space Administration
Goddard Space Flight Center; Lewis

CEEE Sponsors (cont'd.)

Research Center
Nuclear Regulatory Commission
Department of Transportation

National Highway Traffic Safety
Administration
MIMIC Consortium
Various Federal Government Agencies



U.S. DEPARTMENT OF COMMERCE
NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY

BIBLIOGRAPHIC DATA SHEET

1. PUBLICATION OR REPORT NUMBER NISTIR 4381
2. PERFORMING ORGANIZATION REPORT NUMBER
3. PUBLICATION DATE August 1990

TITLE AND SUBTITLE

Center for Electronics and Electrical Engineering Technical Progress Bulletin Covering
Center Programs, January to March 1990, with 1990 CEEE Events Calendar

AUTHOR(S)

J. A. Gonzalez, compiler

PERFORMING ORGANIZATION (IF JOINT OR OTHER THAN NIST, SEE INSTRUCTIONS)

U.S. DEPARTMENT OF COMMERCE
NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY
Gaithersburg, MD 20899

7. CONTRACT/GRANT NUMBER

8. TYPE OF REPORT AND PERIOD COVERED
January-March 1990

SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (STREET, CITY, STATE, ZIP)

SUPPLEMENTARY NOTES

All technical information included in this document has been approved for publication
previously.

ABSTRACT (A 200-WORD OR LESS FACTUAL SUMMARY OF MOST SIGNIFICANT INFORMATION. IF DOCUMENT INCLUDES A SIGNIFICANT BIBLIOGRAPHY OR
LITERATURE SURVEY, MENTION IT HERE.)

This is the thirtieth issue of a quarterly publication providing information on the
technical work of the National Institute of Standards and Technology (formerly the
National Bureau of Standards) Center for Electronics and Electrical Engineering. This
issue of the CEEE Technical Progress Bulletin covers the first quarter of calendar year
1990. Abstracts are provided by technical area for both published papers and papers
approved by NIST for publication.

KEY WORDS (6 TO 12 ENTRIES; ALPHABETICAL ORDER; CAPITALIZE ONLY PROPER NAMES; AND SEPARATE KEY WORDS BY SEMICOLONS)

antennas; electrical engineering; electrical power; electromagnetic interference;
electronics; instrumentation; laser; magnetics; microwave; optical fibers; semicon-
ductors; superconductors

AVAILABILITY

UNLIMITED

FOR OFFICIAL DISTRIBUTION. DO NOT RELEASE TO NATIONAL TECHNICAL INFORMATION SERVICE (NTIS).

ORDER FROM SUPERINTENDENT OF DOCUMENTS, U.S. GOVERNMENT PRINTING OFFICE,
WASHINGTON, DC 20402.

ORDER FROM NATIONAL TECHNICAL INFORMATION SERVICE (NTIS), SPRINGFIELD, VA 22161.


14. NUMBER OF PRINTED PAGES

36

15. PRICE

A03

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300



NIST / CEEE / MAY 90

KEY CONTACTS

Center Headquarters (720)

Electromagnetic Fields Division (723)

Electromagnetic Technology Division (724)

Semiconductor Electronics Division (727)

Electricity Division (728)

Director, Mr. Judson C. French (301) 975-2220

Deputy Director, Mr. Robert I. Scace (301) 975-2220

Chief, Dr. Ramon C. Baird (303) 497-3131

Chief, Dr. Robert A. Kamper (303) 497-3535

Chief, Mr. Frank F. Oettinger (301) 975-2054

Chief, Dr. Oskars Petersons (301) 975-2400

INFORMATION:

For additional information on the Center for Electronics and Electrical Engineering, write or call:

Center for Electronics and Electrical Engineering
National Institute of Standards and Technology
Metrology Building, Room B-358
Gaithersburg, MD 20899
Telephone (301) 975-2220